

5	Electricity supply and wiring shall be maintained in safe condition.	Yes
6	Safe exit for employees during the fire shall be provided.	Yes
7	All staff and employees shall be kept free from any obstruction for free passage in case of any emergency.	Yes
8	All the internal staircases, lift, lobbies and corridors should be adequately ventilated and illuminated.	Yes
9	If the school is provided with central Air conditioning system, all safety measures as per clause 10.1 of IS 14435:1997 should be followed.	Yes
10	School Building shall be kept free from inflammable and toxic material. If storage is inevitable, they should be stored safely.	Yes
11	Any Hazardous/Combustible Material/Highly Flammable Liquids shall not be stored in the school buildings.	Yes
12	DOs and DON'Ts in case of any fire/emergency shall be properly displayed at Strategic locations of the building.	Yes
13	Auto Glow Sign Boards shall be provided indicating Exits/Escapes/Routes.	Yes
14	Electric Wiring in the entire building shall be checked and certified by competent authority.	Yes
15	Structural Stability of the building shall be checked and certified by the competent authority.	Yes
16	Public Address System shall be provided for use in case of any emergency and this system shall cover the entire building.	Yes
17	Detailed information regarding the number of Students in each Class Room and the number of teachers/employees working shall be displayed at Strategic locations of the building.	Yes
18	Display all Emergency supporting numbers such as nearest Fire Stations, Police Stations, Hospitals, Ambulance etc. on all floors and at Strategic locations.	Yes
19	A pictorial map with the details of Entries/Exits, details of Class Rooms/Laboratories/Staff Rooms and Open Place (Assembly Point) of the School Building shall be prepared and displayed in Strategic Locations.	Yes
20	If Basement area of the building exceeds 200 square meters, required to provide Automatic Sprinkler system as per IS 15105:2002.	Yes

We Oakley International School Management/Correspondent hereby certify that the information furnished is correct and if it is noticed at any time that the information provided is false, we understand that our school affiliation may be cancelled by the Concerned Authority. We have instilled fire safety measures as per the Annexure I and undertake to maintain the same in good working condition at all times.

Signature with date of School Authority and Seal
Name & Designation

Copy to :
The Divisional Fire Officer of concerned District.

Mandal Educational Officer
Mdl:Cherial, Dist: Siddipet

Scanned with CamScanner

2. The school building shall not be housed in temporary structures with roofs of tent, thatched or any other combustible materials. It should be ensured that the available Fire Safety Equipment is always in good working condition.

SELF-ASSESSMENT FORM

Self-Assessment of Fire Safety Measures by School Management

a) General Information for School Buildings

Sl. No.	Details	
1	Name of the school	
2	Address of the school	
3	Name of the person in charge	
4	Telephone Number and email of the Authority	
5	Year of construction	
6	Number of floors	
7	Area of the plot (in square meters)	
8	Building area of each floor (in sq. mtrs.) Ground Floor (in square meters) Upper Floor (in square meters)	
9	No. of exits	
10	Width of each staircase	
11	Open spaces Front (in square meters) Side 1 (in square meters) Side 2 (in square meters) Rear (in square meters)	

b) Fire Fighting Equipments

Sl. No.	Fire equipment required	Scale of fire equipment as per Norms	Required	Provided Yes/No
1	Fire Extinguishers (IS 2190:2010)	Two 09 liters water expelling extinguishers or ABC 4 kgs fire extinguisher, for every 200 square meters with minimum of 04 extinguishers per compartment/floor. The extinguisher should be so located as to be available within 151 meter radius.	4	Yes

Signature with Date
School Authority and Seal

m) General Fire Safety Measures which should be followed by the schools not covered under Section 13 of Telangana Fire Service Act 1999, that is, schools which are less than 6 miles in radius or having plot area less than 500 sq.mtrs.

Sl. No.	General Fire Safety Measures	Whether followed Yes / No
1	The school building shall not be housed in temporary structures with roofs of tent, thatched or any other combustible materials	Yes
2	It should be ensured that the available Fire Safety Equipment is always in good working condition	Yes
3	Pre-School, Kinder Garden and Class/Grade 1 Students shall be located on Ground Floor/level of Exit/discharge and Class/Grade 2 Students shall be located not above One Floor higher than Ground Floor/level of Exit/discharge	Yes

Mandal Educational Officer
Mdl:Cherial, Dist: Siddipet

PRINCIPAL
OAKLEY INTERNATIONAL SCHOOL
Near Gandhi Chowk,
Siddipet (T.G.)
Contd/-2